

# Sectoral Water Efficiency Benchmarks

Sector	Median Value
Office Buildings (with Water-Cooled Cooling Tower)	1.0 m <sup>3</sup> / m <sup>2</sup> / year
Retail	1.3 m <sup>3</sup> / m <sup>2</sup> / year
	2.5 L / p / d
4-star Hotels (with Water-Cooled Cooling Tower)	0.35 m <sup>3</sup> / Guestnight
5-star Hotels (with Water-Cooled Cooling Tower)	0.62 m <sup>3</sup> / Guestnight
Primary Schools	10.6 L / p / d
Secondary Schools	12.8 L / p / d
Junior Colleges	11.5 L / p / d
Data Centres	2.4 m <sup>3</sup> / MWh
Commercial Laundries	13.5 m <sup>3</sup> / tonne
	Average Recycling Rates (%)
Wafer Fabrication Plants	43%
Semiconductors (Excluding Wafer Fabrication Plants)	27%
Biomedical Manufacturing	14%

## Disclaimer:

The figures indicated in the table may exclude tenants' usage.