



- NOTES:
1. THE FLOOR WASTE SHALL NOT BE SMALLER THAN 50mm IN DIAMETER
 2. FLOOR TRAP SHALL NOT RECEIVE FLOW FROM DIFFERENT PREMISES/UNITS/ROOMS, EXCEPT WHERE APPROVED BY PUB (i.e. BALCONY & AHU)

ALL DIMENSIONS ARE IN mm.

ISSUED : DEC 2021	SCALES
LAST REVIEWED : NOV 2021	NOT TO SCALE

DISCHARGE PIPE & FLOOR WASTE CONNECTION ON GROUND LEVEL


SINGAPORE'S NATIONAL WATER AGENCY
 WATER RECLAMATION (NETWORK) DEPARTMENT
 DRAWING NO. 3-2b