



**NOTES :**

1. NO uPVC PIPE IS TO BE USED FOR SEWER CONNECTION BETWEEN LAST INSPECTION CHAMBER AND MANHOLE AND MIN. SIZE IS Ø200mm\*
2. RECOMMENDED GRADIENT : SEE DRAWING NO. 3-1b

ALL DIMENSIONS ARE IN mm.

ISSUED : MAR 2000	SCALES
REVIEWED : JAN 2019	NOT TO SCALE

**BACKDROP AND TUMBLING BAY DETAILS**