



**NOTES :**

1. THE SECTION OF DRAIN-LINE CONNECTION FROM LAST IC TO A MANHOLE SHALL BE MINIMUM DIA. 200MM AND NO uPVC PIPE SHALL BE USED.
2. THE DRAIN-LINE CONNECTION TO IC/MH SHALL COMPLY WITH REQUIREMENTS IN TABLE BELOW

Dia. of drainline	Maximum Gradient	Minimum Gradient
150mm/200mm	1: 70	1: 90

ALL DIMENSIONS ARE IN mm.

ISSUED : DEC 2021	SCALES
LAST REVIEWED : NOV 2021	NOT TO SCALE

BACKDROP AND TUMBLING BAY DETAILS

 SINGAPORE'S NATIONAL WATER AGENCY  
 WATER RECLAMATION (NETWORK) DEPARTMENT  
 DRAWING NO. 3-4b