



NOTES :

- (1) COMPACTED GRANULAR BACKFILLING SHALL BE FREE FROM LUMPS/STONE COMPACTED IN EACH LAYERS OF LESS THAN 150mm.
- (2) FOUNDATION STRUCTURE AND PILING SHOULD BE DESIGNED BY A PE
- (3) CONCRETE GRADE FOR FOUNDATION SHALL BE MINIMUM C28/35
- (4) CONCRETE GRADE FOR HAUNCHING AND BENCHING SHALL BE MINIMUM C20/25
- (5) CONCRETE GRADE FOR LEAN CONCRETE SHALL BE MINIMUM C12/15

ALL DIMENSIONS ARE IN mm.

ISSUED : DEC 2021

SCALES

NOT TO SCALE

LAST REVIEWED : NOV 2021

TYPE BEDDING FOR DRAIN - LINE & DISCHARGE PIPE

OPUB SINGAPORE'S NATIONAL WATER AGENCY
WATER RECLAMATION (NETWORK) DEPARTMENT

DRAWING NO. 3-5b