



NOTES :

1. NO uPVC PIPE IS TO BE USED FOR SEWER CONNECTION BETWEEN LAST INSPECTION CHAMBER AND MANHOLE AND MIN. SIZE IS $\varnothing 200\text{mm}$
2. RECOMMENDED GRADIENT : SEE DRAWING NO. 3-1
3. * MIN 200MM DIA. FOR SEWER CONNECTION TO MANHOLE

ALL DIMENSIONS ARE IN mm.

BACKDROP AND TUMBLING BAY DETAILS