



Ø100mm VENTILATING STACKS TO TERMINATE IN OPEN AIR (REFER TO CLAUSE 4.3.6) WITH THE FOLLOWING MINIMUM HEIGHT:

- (I) 150mm ABOVE HIGHEST SLOPING ROOF.
- (II) 150mm ABOVE THE PARAPET WALL OF FLAT ROOF.
- (III) 2500mm ABOVE ROOF AREAS DESIGNATED FOR COMMON USE.

ROOF

UPPER STOREY

THIRD STOREY

SECOND STOREY

FIRST STOREY/GROUND FLOOR

LEGEND :

- wc (p) — WATER CLOSET-PEDESTAL
- lb — LONG BATH
- wb — WASH BASIN
- ft — FLOOR TRAP
- fw — FLOOR WASTE
- u — URINAL
- ut — URINAL TRAP

- Note:** 1. FLOOR TRAP SERVING KITCHEN SINK SHALL NOT BE CONNECTED TO DISCHARGE STACK/PIPE RECEIVING FLOW FROM TOILET.
 2. FOR BUILDING > 30 STOREY, SIZE OF DISCHARGE STACK & VENTILATING STACK SHALL BE CALCULATED BASED ON BS EN12056-2 TABLE 2 SYSTEM 1.

ALL DIMENSIONS ARE IN mm.