



NOTE:

THE VENT PIPE SHALL BE CONNECTED TO THE VENTILATING STACK ABOVE THE OVERFLOW LEVEL OF THE FLOOR TRAP.

ALTERNATIVE VENTILATING PIPE ARRANGEMENT BELOW THE SLAB WHEN PIPE (a) IS NOT FEASIBLE. THE CONNECTION TO THE NEAREST VENTILATING STACK SHALL BE AS SHORT AS POSSIBLE

ALL DIMENSIONS ARE IN mm.

ISSUED : MAR 2000	SCALES
REVIEWED : JAN 2019	NOT TO SCALE

**VENTILATING PIPE FOR FLOOR TRAP CONNECTION TO DISCHARGE PIPE
(WITHOUT WATER CLOSET CONNECTION)**