



Type of Appliance	Minimum Internal Diameter of Waste Pipe in mm	Maximum Number of Waste Sanitary Appliances Allowed on Common Waste Pipe (Connected in Series)	
		Minimum Internal Diameter of Common Waste Pipe in mm	
		50	75
Laboratory Sink	40	2	6
Longbath / Shower Tray	40	-	-
Sink (single or double bowl)	40	2	6
Wash Basin	32	3	10
Wash Trough / Custom-made Sink	50	2	6
Wash Tub	50	2	6

ISSUED : MAR 2000

REVIEWED : JAN 2019

SCALES

NOT TO SCALE

VENT PIPE ARRANGEMENTS FOR 3 OR MORE WASH BASINS CONNECTED IN SERIES AND COMMON WASTE PIPE SIZE FOR SANITARY APPLIANCE CONNECTED IN SERIES