



- NOTES : 1) Floor trap requirements :-
- (a) Water Seal: min 50mm
 - (b) Passage clearance = dia of outlet (min 75mm)
 - (c) Dia of outlet = min 75mm dia (min 100mm dia for direct connection to inspection chamber)
- 2) Floor trap should be securely installed by embedding in concrete

ALL DIMENSIONS ARE IN mm.

FLOOR TRAP (FOR CONNECTION TO INSPECTION CHAMBER)