



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED.
  2. THE CONTRACTOR HAS TO REFER TO THE GENERAL NOTES IN DRAWING NO. PUB/WSN/001.
  3. ALL CHAMBERS SHALL BE DESIGNED AND ENDORSED BY A PROFESSIONAL ENGINEER (P.E.) ENGAGED BY A CONTRACTOR.
  4. SAFETY CAGES SHALL BE INSTALLED FOR ALL STAINLESS STEEL LADDERS (GRADE 304) EXCEEDING 3M HEIGHT.

DRAWING NO.: PUB/WSN/STD/318			
REV.	DATE	SCALE: 1:10	REV.: -

**AIR VALVE CHAMBER FOR 500MM DIA. DUCTILE IRON PIPELINE**